

**SIMPLIFIED TEST CERTIFICATE****Nº. 210318-01/EN****ITE**  
INSTITUTO TECNOLÓGICO DE  
LA ENERGÍA

**Product** Single phase static meter bi-directional, to measure active and reactive energy, direct connection for indoor installation.

**Trade Mark** SAGEMCOM

**Model** XS211 253905824

**Manufacturer** SAGEMCOM ENERGY & TELECOM, SAS

**Tested on request of** SAGEMCOM ENERGY & TELECOM, SAS  
250 Route de l'Empereur  
92848 Rueil-Malmaison FRANCE

**Description**

Voltage range	240
Current range	5(100)A
Frequency	50 Hz
Accuracy class	Active: Cl. 1 (kWh); Reactive: Cl 2 (kvarh)
Meter constant	1500 imp/kWh; 1500 imp/varh
Temperature range	[-40°C ÷ +70°C]

Hardware version	Software version
<b>PCBA: 253903101</b> <b>PCB: 253903099-B</b>	<b>MTR: 02.31</b> <b>CRC: 0x0D823B49</b>

**Standard** IEC 62052-11: 2003, IEC 62053-21 and EN 62053-23: 2003

**Test certificate based on the test report** IE-ITE-210318-01/EN

**Test results** The equipment described above has passed all applicable tests according to the standard indicated and listed in the test reports described in the above paragraph. This document attests that the evaluated equipment, subjected to all the type tests and verifications prescribed by the normative reference documents, was found in conformity with them.

*Note: The complete results are contained in the original/s test reports available to the customer with no. IE-ITE-210318-01/EN. This test certificate is exclusively referred to samples subjected to test identified on the test report. This sample was tested in the manner and the date pointed out in the same report. This document has been digitally signed and its validity must be checked with the digital certificate inserted in the pdf file. Reproduction by any other means shall be considered a copy of the original.*

*Authorized signatory:*

MANAGER OF LOW VOLTAGE AND INTEROPERABILITY AREA

**INSTITUTO TECNOLÓGICO DE LA ENERGÍA (ITE)**

**Centro Tecnológico CT nº 74**

Domicilio Social  
Campus de la U.P.V.  
Edificio Institutos 2  
Camino de Vera, s/n  
Valencia

**Sede Central**  
**Contabilidad, facturas, correspondencia**  
Parque Tecnológico de Valencia  
Av. Juan de la Cierva, 24  
46980 Paterna (Valencia)

Tel.: +34 96 136 66 70 Fax: +34 96 136 66 80  
www.ite.es · ite@ite.es

Page 1 of 1  
Issuing date: 21/05/2021

A85PG10EN R0